Lesson Plan General Industry Training Program (10-hour)

Topic: Flammable and Combustible Liquids

Overview of the OSHA Standard

This standard applies to the handling, storage and use of flammable and combustible liquids with a flash point below 200⁰ F. There are two primary hazards associated with flammable and combustible liquids: explosion and fire. In order to prevent these hazards, this standard addresses the primary concern of design and construction, ventilation, ignition sources and storage.

Step 1: Planning the Lesson

- Instructional Materials.
 - 1. PowerPoint presentation
 - 2. Instructor notes.
 - 3. Other materials.

• Instructional Objectives.

- 1. Complete the required topics for the OSHA 10-hour course.
- 2. Complete the following optional topics:
 - a.
 - h.
 - c
- 3. Present Flammable and Combustible Liquids to [number] participants.
- 4. Incorporate active participation in each lesson.
- 5. Provide a guiz or short evaluation at the end of the course.
- 6. Ensure feedback from participants at various points in the training.
- Guest Speakers/Presenters and Topics/Responsibilities.

Step 2: Presenting the Lesson

• Lesson Introduction

Introductory remarks or transition from previous lesson.

- Learning Objectives/Outcomes.

Upon completion of the lesson, participants will be able to:

1. Define flash point, flammable liquid, and combustible liquid.

Possible responses.

- The **flash point** is the minimum temperature at which a liquid gives off enough vapor to form an ignitable mixture.
- Flammable liquids have flash points below 100⁰ F.
- Combustible liquids have flash points at or above 100° F.

Learning Objectives/Outcomes (Continued)

2. Explain at least 2 ways to avoid explosion or fire from flammable or combustible liquids.

Possible responses.

- Practice safe handling, storage, fire control and ventilation.
- Ensure flammables and combustibles are properly stored.
- Always handle and transfer flammable or combustible liquids using proper containers; or through proper transfer systems that employ a safety faucet, a safety pump, or a closed piping system.
- 3. List 4 potential sources of ignition for flammable and combustible liquids.

Possible responses.

- open flames
- smoking
- static electricity
- cutting and welding

- hot surfaces
- electrical and mechanical sparks
- lightning
- 4. Identify at least 2 actions that apply to each of the 4 components of a good plan for safe use of flammable and combustible liquids.

Possible responses.

- Control of Ignition Sources
- a. Identify sources of ignition.
- b. Always use bonding and grounding when transferring flammable liquids into/from containers.
- c. Always provide adequate ventilation to reduce the potential for ignition.

• Proper Storage

- a. Identify compatible chemicals.
- b. Isolate and separate incompatible materials.
- c. Ensure storage doesn't limit safe egress.
- d. Store in proper area, cabinet, or container.
- e. Label storage areas/cabinets.
- f. Store waste and residue in covered containers and dispose of daily.

- Learning Objectives/Outcomes (Continued)
 - Fire Control

- a. Ensure proper hoses, fire extinguishers or other fire control devices are available where flammable or combustible liquids are stored.
- b. Do not permit flames or smoking in areas where flammable or combustible liquids are stored.
- c. Store materials that react with water in a room separate from flammable and combustible liquids.

• Safe Handling

- a. Transfer by means of a safety pump.
- b. Transfer by gravity through an approved self-closing safety faucet.
- c. Transfer through a closed piping system.
- d. Transfer from safety cans.
- Planned Activities, Discussion or Participant Interaction.

Step 3: Evaluating Student Learning and Instruction

· Lesson Evaluation and Comments.

References

OSHA Standard

- 29 CFR 1910.106 Subpart H Flammable and Combustible Liquids (1910.106)
 - http://www.osha-slc.gov/OshStd_data/1910_0106.html

OSHA Publications

- http://www.osha-slc.gov/OshDoc/Additional.html
- 3088 How to Prepare for Workplace Emergencies

OSHA References/Resources

- OSHA's Small Business Outreach Training Program, Flammable and Combustible Liquids
 - http://www.osha-slc.gov/SLTC/smallbusiness/sec8.html
- OSHA Technical Links Ventilation
 - http://www.osha-slc.gov/SLTC/ventilation/index.html
- Self-Inspection Checklists
 - http://www.osha-slc.gov/SLTC/smallbusiness/chklist.html#Flammable